

WATER SAMPLING TEST RESULTS 2019-2022

TYPE OF FIXTURES TESTED: WATER FOUNTAIN KITCHEN FAUCET WATER COOLER (CHILLER UNIT) BATHROOM FAUCET CLASSROOM FAUCET WATER MAIN VALVE NURSE'S OFFICE SINK				OUTLET TYPE: PORCELAIN STAINLESS PLASTIC		ALLOWABLE LIMITS: LEAD: 0.005MG/L COPPER: 1.0mg/L	
SCHOOL	ADDRESS	# LOCATIONS TESTED	# OVER ALLOWABLE LIMIT	IMMEDIATE MEASURES TAKEN	CORRECTIVE MEASURES: AERATOR REPLACEMENT/ FLUSH & RETEST	CORRECTIVE MEASURES: FIXTURE REPLACEMENT	CORRECTIVE MEASURES: PIPE REPLACEMENT
Acadia School	175 Killarney Ave.	44	12	DO NOT USE/DRINK SIGNS POSTED	10 REPAIRED REPLACE 2 FIXTURES	2 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022	
AA Leach School	1827 Chancellor Dr.	79	14	DO NOT USE/DRINK SIGNS POSTED	8 REPAIRED REPLACE 6 FIXTURES		
Bairdmore School	700 Bairdmore Blvd.	19	4	DO NOT USE/DRINK SIGNS POSTED	2 REPAIRED REPLACE 2 FIXTURES	2 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022	
Beaumont School	5880 Betsworth Ave.	26	3	DO NOT USE/DRINK SIGNS POSTED	2 REPAIRED REPLACE 1 FIXTURES		
Beaverlodge School	6691 Rannock Ave.	37	8	DO NOT USE/DRINK SIGNS POSTED	3 REPAIRED REPLACE 5 FIXTURES	5 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022	
Bonnycastle School	1100 Chancellor Dr.	29	3	DO NOT USE/DRINK SIGNS POSTED	REPLACE 3 FIXTURES	3 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022	
Chancellor School	1520 Chancellor Dr.	33	7	DO NOT USE/DRINK SIGNS POSTED	3 REPAIRED REPLACE 4 FIXTURES	4 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022	
Charleswood School	505 Oakdale Dr.	70	6	DO NOT USE/DRINK SIGNS POSTED	REPLACE AERATORS & RETEST		
Crane School	888 Crane Ave.	38	1	DO NOT USE/DRINK SIGNS POSTED	1 REPAIRED	NO FURTHER ACTION REQUIRED	N/A
Dalhousie School	262 Dalhousie Dr.	25	9	DO NOT USE/DRINK SIGNS POSTED	7 REPAIRED REPLACE 1 FIXTURE, 1 FOUNTAIN	1 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022 REPLACE 1 FOUNTAIN	
Dieppe School	530 Dieppe Rd.	37	5	DO NOT USE/DRINK SIGNS POSTED	1 REPAIRED 1 FIXTURE REMOVED REPLACE 2 FIXTURES	2 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022	
Ft. Richmond Collegiate	99 Killarney Ave.	47	7	DO NOT USE/DRINK SIGNS POSTED	3 REPAIRED, 1 FIXTURE REMOVED REPLACE 2 FIXTURES REMOVE 1 FOUNTAIN		
General Byng School	1250 Beaumont St.	59	6	DO NOT USE/DRINK SIGNS POSTED	1 FIXTURE REPAIRED REPLACE 5 FIXTURES	2 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022 3 FIXTURES LOCATED IN SCIENCE LABS – NOT REPLACED.	

WATER SAMPLING TEST RESULTS 2019-2022

SCHOOL	ADDRESS	# FIXTURES TESTED	# OVER ALLOWABLE LIMIT	IMMEDIATE MEASURES TAKEN	CORRECTIVE MEASURES AERATOR REMOVAL/FLUSH	CORRECTIVE MEASURES FIXTURE REPLACEMENT	CORRECTIVE MEASURES PIPE REPLACEMENT
Henry G. Izatt School	960 Scurfield Blvd.	63	12	DO NOT USE/DRINK SIGNS POSTED	4 REPAIRED REPLACE 8 FIXTURES	1 FIXTURE REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022 7 FIXTURES STILL TO BE REPLACED	
Laidlaw School	515 Laidlaw Blvd.	39	6	DO NOT USE/DRINK SIGNS POSTED	1 REPAIRED 1 FOUNTAIN REMOVED REPLACE 4 FIXTURES	4 FIXTURES REPLACED ON OCT 2021 RETEST TO OCCUR IN MAY 2022	
Linden Meadows School	335 Lindenwood Dr.	49	8	DO NOT USE/DRINK SIGNS POSTED	4 REPAIRED REPLACE 4 FIXTURES	1 FIXTURE REPLACED ON OCT 2021 RETEST TO OCCUR IN MAY 2022 3 FIXTURES STILL NEED TO BE REPLACED	
Oak Park	820 Charleswood	108	25	DO NOT USE/DRINK SIGNS POSTED			
Oakenwald School	666 Oakenwald Ave.	36	4	DO NOT USE/DRINK SIGNS POSTED	3 REPAIRED; REPLACE 1 FIXTURE	1 FIXTURE REPLACED ON OCT 2021 RETEST TO OCCUR IN MAY 2022	
Pacific Junction School	715 Cathcart St.	29	5	DO NOT USE/DRINK SIGNS POSTED	1 REPAIRED REPLACE 4 FIXTURES	4 FIXTURES REPLACED ON OCT 2021 RETEST TO OCCUR IN MAY 2022	
Pt Alternative School	315 Chancellor Matheson Rd.	8	1	N/A	NOTIFIED PROPERTY OWNER	NO FURTHER ACTION REQUIRED.	
PTEC	100 Innovative Dr.	2	0	N/A	NO FURTHER ACTION REQUIRED	-	-
Ralph Maybank School	20 Donnelly St.	26	1	DO NOT USE/DRINK SIGNS POSTED	REPLACE 1 FIXTURE	1 FIXTURE REPLACED ON OCT 2021 RETEST TO OCCUR IN MAY 2022	
River West Park School	30 Stack St.	33	9	DO NOT USE/DRINK SIGNS POSTED	5 REPAIRED REPLACE 4 FIXTURES	2 FIXTURES REPLACED ON OCT 2021 RETEST TO OCCUR IN MAY 2022 2 FIXTURES STILL NEED TO BE REPLACED	
Royal School	450 Laxdal Rd.	36	12	DO NOT USE/DRINK SIGNS POSTED	9 REPAIRED REPLACE 3 FIXTURES REPLACE 1 FOUNTAIN	2 FIXTURES REPLACED ON OCT 2021 RETEST TO OCCUR IN MAY 2022 1 FOUNTAIN STILL NEEDS TO BE REPLACED 1 FIXTURE STILL NEEDS TO BE REPLACED	
Ryerson School	10 Ryerson Ave.	29	2	DO NOT USE/DRINK SIGNS POSTED	1 REPAIRED REPLACE 1 FIXTURE	1 FIXTURE REPLACED ON OCT 2021 RETEST TO OCCUR IN MAY 2022	
Shaftesbury School	2240 Grant Ave	92	14	DO NOT USE/DRINK SIGNS POSTED	2 REPAIRED 12 FIXTURES ARE LOCATED IN SCIENCE ROOMS	12 SCIENCE/BIOLOGY ROOM FIXTURES NEED REPLACING.	
South Point School	615 Kirkbridge	120	0	N/A	NO FURTHER ACTION REQUIRED	-	-
St-Avila School	633 Patricia Ave.	21	3	DO NOT USE/DRINK SIGNS POSTED	2 REPAIRED REPLACE 1 FIXTURE		

WATER SAMPLING TEST RESULTS 2019-2022

SCHOOL	ADDRESS	# FIXTURES TESTED	# OVER ALLOWABLE LIMIT	IMMEDIATE MEASURES TAKEN	CORRECTIVE MEASURES AERATOR REMOVAL/FLUSH	CORRECTIVE MEASURES FIXTURE REPLACEMENT	CORRECTIVE MEASURES PIPE REPLACEMENT
Tuxedo Park School	2300 Corydon Ave.	17	7	DO NOT USE/DRINK SIGNS POSTED	2 REPAIRED 2 FOUNTAINS REPLACED REPLACE 3 FIXTURES	FOUNTAINS REPLACED SEPT 2021 1 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022 3 FIXTURES STILL NEED TO BE REPLACED	
Van Wallegem School	1 Princemere Dr.	46	2	DO NOT USE/DRINK SIGNS POSTED	REPLACE 2 FIXTURES;	1 FIXTURE REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022 1 FIXTURE/BOILER ROOM DOES NOT NEED TESTING.	
Vincent Massey School	975 Dowker St	91	23	DO NOT USE/DRINK SIGNS POSTED	2 REPAIRED REPLACE 6 FIXTURES 15 SCIENCE FIXTURES NOT REPLACED		
Viscount Alexander School	810 Waterford Ave.	38	7	DO NOT USE/DRINK SIGNS POSTED	3 REPAIRED REPLACE 4 FIXTURES	3 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022 1 FIXTURE STILL NEEDS TO BE REPLACED	
Westdale School	6720 Betsworth Ave.	39	10	DO NOT USE/DRINK SIGNS POSTED	6 REPAIRED REPLACE 4 FIXTURES	3 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022 1 FIXTURE STILL NEEDS TO BE REPLACED.	
Westgrove School	50 Westgrove Way	27	11	DO NOT USE/DRINK SIGNS POSTED	6 REPAIRED REPLACE 5 FIXTURES	4 FIXTURES REPLACED OCT 2021 RETEST TO OCCUR IN MAY 2022 1 FIXTURE STILL NEEDS TO BE REPLACED	
Whyte Ridge School	400 Scurfield Blvd.	51	2	DO NOT USE/DRINK SIGNS POSTED	1 REPAIRED REPLACE 1 FIXTURES	1 FIXTURE REPLACED ON OCT 2021 RETEST TO OCCUR IN MAY 2022	