

| SCHOOL NAME | GYM SIZE Playable Area (sq. ft.) | GYM SIZE Playable Area (sq. m.) | Occupant Load (Calculated based only as open area, sq.m/0.75) | No. of Exits | No. of Doors | Exit Capacity | Maximum Occupant Load - Standing | Maximum Occupant Load - Audience (seating and stages) Up to 50 additional performers on stage | NOTES |
|---------------------------------|--|---------------------------------------|--|---|-----------------|---------------------|-------------------------------------|---|---|
| ACADIA | 6188 | 574.88 | 766.51 | 3 | 6 | 6 @ 914/8 = 685.5 | 685 | 630 | *Using risers as stage |
| ARTHUR A. LEACH | 5935 | 551.38 | 735.17 | See Architect Load calculation Package | | | 488 | 438* | *Limited by exit widths |
| BAIRDMORE | 6050 | 562.06 | 749.42 | 4 | 8 | 8 @ 914/8 = 914 | 800 | 572* | *Using risers as stage |
| BEAUMONT | 4183 | 388.61 | 518.15 | 4 | 6 | 6 @ 914/6.1 = 899 | 518 | 360 | |
| BEAVERLODGE | 3960 | 367.90 | 490.53 | 2 | 4 | 4 @ 914/6.1 = 599 | 490 | 338 | |
| BISON RUN | 7102 | 659.80 | 879.73 | See Life Safety Drawings in School Construction Drawing Set | | | 827 | 736 | |
| BISON RUN (MPR) | 2811 | 261.15 | 348.20 | See Life Safety Drawings in School Construction Drawing Set | | | 200 | | |
| CHANCELLOR | 5144 | 477.89 | 637.19 | 4 | 8 | 8 @ 914/8 = 914 | 637 | 572* | *Using risers as stage |
| CHARLESWOOD | 6781 | 629.98 | 839.97 | 4 | 9 | 9 @ 914/6.1 = 1348 | 839 | 598 | |
| CRANE | 2490 | 231.33 | 308.44 | 3 | 4 | 4 @ 914/6.1 = 599 | 308 | 180* | *Using option #2 |
| DALHOUSIE | 4925 | 457.55 | 610.06 | See Architect Load calculation Package | | | 600 | 500 | |
| DIEPPE SCHOOL | 3931 | 365.20 | 486.94 | 3 | 6 | 6 @ 914/6.1 = 899 | 486 | 400* | *Using built-in stage |
| FORT RICHMOND | 7217 | 670.48 | 893.97 | See Architect Load calculation Package | | | 900 | 644 | |
| GENERAL BYNG | 4914 | 456.53 | 608.70 | See Architect Load calculation Package | | | 599 | 400 | |
| HENRY G. IZATT | 5593 | 519.61 | 692.81 | 3 | 6 | 6 @ 914/8 = 685.5 | 685 | 598* | *Using risers as stage |
| LAIDLAW | 4000 | 371.61 | 495.48 | 2 | 4 | 4 @ 914/6.1 = 599 | 495 | 340 | |
| LINDEN MEADOWS | 4136 | 384.25 | 512.33 | See Architect Load calculation Package | | | 515 | 360 | *Using option #2 |
| LINDEN MEADOWS (MINI GYM) | 1440 | 133.78 | 178.37 | See Architect Load calculation Package | | | 100 | | |
| OAK PARK HIGH | 7008 | 651.06 | 868.09 | See Architect Load calculation Package | | | 700 | 576 | |
| OAKENWALD | 2490 | 231.33 | 308.44 | 3 | 4 | 4 @ 914/6.1 = 599 | 308 | 180* | *Using option #2 |
| PACIFIC JUNCTION | 3970 | 368.83 | 491.77 | 2 | 4 | 4 @ 914/6.1 = 599 | 491 | 330 | |
| PACIFIC JUNCTION | 1457 | 135.36 | 180.48 | 1 | 1 | 1 @ 914/6.1 = 149 | 60 | | Limited because of 1 exit |
| PEMBINA TRAILS COLLEGIATE | 9235 | 857.96 | 1143.95 | See Life Safety Drawings in School Construction Drawing Set | | | 1144 | 810 | |
| PEMBINA TRAILS COLLEGIATE (MPR) | 2906 | 269.98 | 359.97 | See Life Safety Drawings in School Construction Drawing Set | | | 360 | | |
| PRAIRIE SUNRISE | 5390 | 500.75 | 667.66 | 3 | 6 | 6 @ 914/8 = 685.5 | 667 | 520 | |
| RALPH MAYBANK | 2377 | 220.83 | 294.44 | 2 | 3 | 2 @ 914/6.1 = 299 | 294 | 165 | 2 exit rule applies, limited by single door |
| RHG BONNYCASTLE | 3689 | 342.72 | 456.96 | See Architect Load calculation Package | | | 600 | 286 | |
| RHG BONNYCASTLE (MINI-GYM) | 1712 | 159.05 | 212.07 | See Architect Load calculation Package | | | 59 | | Limited because of 1 exit |
| RIVER WEST PARK | 4182 | 388.52 | 518.03 | 2 | 4 | 4 @ 914/6.1 = 599 | 518 | 308 | |
| ROYAL | 5400 | 501.68 | 668.90 | 3 | 6 | 6 @ 914/8 = 685.5 | 668 | 520 | |
| SHAFTESBURY | 6620 | 615.02 | 820.02 | See Architect Load calculation Package | | | 700 | 600 | |
| SOUTH POINTE | 5973 | 554.91 | 739.88 | See Life Safety Drawings in School Construction Drawing Set | | | 620 | 576 | |
| ST. AVILA | 5017 | 466.09 | 621.46 | 3 | 5 | 5 @ 914/8 = 571 | 450 | 400 | |
| TUXEDO PARK | 2469 | 229.38 | 305.84 | 3 | 4 | 4 @ 914/8 = 457 | 305 | 168 | |
| VAN WALLEGHEM | 4078 | 378.86 | 505.14 | 3 | 5 | 5 @ 914/6.1 = 749 | 505 | 340 | |
| VINCENT MASSEY | 9139 | 849.04 | 1132.05 | 6 | 10 | 10 @ 914/6.1 = 1498 | 1132 | 896 | *Using built-in stage |
| VISCOUNT ALEXANDER | 5046 | 468.79 | 625.05 | See Architect Load calculation Package | | | 490 | 440 | |
| WESTDALE SCHOOL | 6601 | 613.25 | 817.67 | 3 | 6 | 6 @ 914/6.1 = 899 | 817 | 644 | |
| WESTGROVE | 5466 | 507.81 | 677.08 | See Architect Load calculation Package | | | 500 | 456 | |
| WHYTE RIDGE | 5134 | 476.96 | 635.95 | 4 | 8 | 8 @ 914/6.1 = 1198 | 540 | 475* | *Using option #2 |
| VERIFIED BY ARCHITECT | | | | | | | | | |
| PRELIMINARY BY PTSD | | | | | | | | | |